Building/Year built: Scotts Valley CC Team: Shelley Zuniga, Dana Esposito

Date: 11/9/15 Job#: R15025

Cite Element: Park Site Yes No n/a Notes:

| Element: (ball field, etc) | How many of each element at this site? | Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes) | AR to element? | Does the AR extend to play surface/both sides of sport court? | Does the AR extend to player seating? | Does the AR extend to spectator seating? | Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance? | total accessible/ total (ex - 0/5) | Notes: RR: Forward unobstructed - 15" to 48" (max 20" over object) forward high obstructed - max 44" for max reach over of 25" over 34" aff counter Side unobstructed - 15" to 48" (max 10" over object) side high obstructed - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54") |
|-------------------------------|--|--|----------------|--|--|--|---|---|---|
| 1. Grill | 1 | Yes | Yes | n/a | n/a | n/a | n/a | 1/1 | , |
| 2. Community Gardens | 49 | Yes | Yes | n/a | n/a | n/a | n/a | 8/49 | 41 plots with 8 raised beds, route through ok, cement and crushed stone (CC79, CC80, CC81, CC82) |
| 3. Garbage Cans | 8 | Yes | Yes | n/a | n/a | n/a | n/a | 8/8 | |

| | Benches: | | How many: 0 How many accessible: |
|----------------------|---|--|----------------------------------|
| | Picnic Tables: | | How many: 0 How many accessible: |
| 1011.2.2 1011.3.3 | Is the surface of the clear space firm and stable with max slope 2.08% in all directions? | | |

Rev: 04/9/2014