

MULTIPLE DOORS CHECKLIST

Cite:	Question:	Door: E Door #: Main entrance	Door: I Door #: Staff restroom	Door: I Door #: public restroom	Door: I Door #: file storage	Door: I Door #: break to storage	Door: I Door #: storage to rec room	Door: E Door #: Break exit	Door: I Door #: Division manager	Door: E Door #: division manager exit
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Storage on pull (SP3)	Yes	No, interior storage and small (SP5)	Storage on pull (SP6)	No, storage on pull (SP27)	No, narrow pad; 10" on pull (SP7 , SP8)	No, chair on pull (SP12)	No, shelf on push (SP13)
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	n/a	n/a	n/a	n/a	n/a	2.2% (SP10 , SP11)	n/a	2.3% (SP14 , SP15)
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	n/a	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	25.5" (SP4)	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	Yes	n/a	n/a	n/a
303.2	Change in level < 1/4"	n/a	Yes	Yes	n/a	n/a	Yes	1.75" (SP9)	n/a	2.25" (SP16)
404.2.5	Thresholds < 1/2 "	1" (SP1)	Yes	Yes	n/a	n/a	n/a	Yes	n/a	Yes
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	No 1"	Yes	Yes	n/a	n/a	n/a	n/a	n/a	Yes
302.2	If carpeted is pile < 1/2"	Yes	n/a	n/a	n/a	n/a	n/a	n/a	No, carpet fraying (SP207 , SP208)	Yes
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	Yes	Yes	n/a	n/a	Yes	n/a	n/a	n/a
309.4;	Door hardware	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

404.2.7	compliant?									
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	Yes	Yes	n/a	n/a	6#	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	6#	n/a	n/a	n/a	n/a	n/a	n/a-broken	n/a	9#
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	No	No	n/a	n/a	No, fast	n/a	n/a	No, fast
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	Yes	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	N/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

	open)									
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Other:										

Rev. 04/21/14

Cite:	Question:	Door: I Door #: School-aged office	Door: I Door #: storage in hall	Door: I Door #: Sports office	Door: I Door #: Rec by entrance	Door: E Door #: Exit to parking in rec	Door: I/E Door #: Exit to park in rec	Door: E Door #: Right storage shed	Door: E Door #: Center storage shed	Door: E Door #: Left storage shed
	If a double door, measure only the active leaf									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No, table on pull (SP210)	No entry (SP19)	No, counter and storage on pull (SP215)	Yes	No, 6" to edge of cement (SP21)	Yes	No, storage (SP28)	Yes	No, storage (SP45)
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	Yes	8.3% (SP25, SP26)	3.8% (SP29, SP30)	9.7% (SP36, SP37)	9.2% (SP40, SP41)
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	22" (SP18)	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	n/a	n/a	n/a	Yes	2.25" (SP23)	Yes	2.5" (SP31)	1" (SP38)	3" (SP44)

404.2.5	Thresholds < ½ "	n/a	n/a	n/a	Yes	Yes	Yes	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	Yes	Yes	Yes	n/a	n/a	n/a
302.2	If carpeted is pile < ½"	Yes	Yes	No, fraying	n/a	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor, <1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Knob (SP20)	Yes	Yes	No, small (SP33)	No, small	No, small
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	48" (SP34)	45" (SP42, SP43)	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a-close broken	n/a	n/a	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a	7#	n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	n/a	n/a	n/a	No, fast	n/a	n/a	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	n/a	Yes	Yes	Yes	Yes	Yes	n/a	n/a	n/a

404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Other:										

Cite:	Question:	Door: E Door #: W park RR	Door: E Door #: M park RR	Door: I/E Door #:	Door: I/E Door #:	Door: I/E Door #:	Door: I/E Door #:	Door: I/E Door #:	Door: I/E Door #:	Door: I/E Door #:
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: 9.5" to sink on push (SP179)	Yes							
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes							
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes							
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes							

404.2.3	If door is 24" D, is it 36" W	n/a	n/a							
303.2	Change in level < 1/4"	n/a	n/a							
404.2.5	Thresholds < 1/2 "	n/a	n/a							
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a							
302.2	If carpeted is pile < 1/2"	n/a	n/a							
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a							
309.4; 404.2.7	Door hardware compliant?	Yes	Yes							
Smart practice	Hazardous areas knurled handle	n/a	n/a							
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes							
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a							
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a							
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a							
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 10#	No: 11#							
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	Yes							
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap	Yes	Yes							

Building/Year built: Skypark/Rec Center
 Date: 11/10/2015

Team: Dana Esposito and Shelley Zuniga
 Job#: R15025

	1/16" max)									
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a							
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a							
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a							
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a							
Other:										