

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
<a href="#">Camp Evers Park</a>	1.1.1	Parking	Repaint stalls to be 18' long and 9' wide and access aisles 5' each with a high quality blue paint	\$52.50	each	1	\$52.50	1
Camp Evers Park	1.1.2	Parking	Paint access aisles with diagonal lines spaced 36" on center in a contrasting color to the surface and "NO PARKING" painted on aisle, min of 12" high	\$52.50	each	1	\$52.50	1
Camp Evers Park	1.1.3	Parking	Paint stall with the symbol of access 36" by 36" and centered in space	\$52.50	each	1	\$52.50	1
Camp Evers Park	1.1.4	Parking	Add one van parking sign to one accessible stall and repaint stall and access aisle to 12' and 5' or 9' and 8'	\$202.50	each	1	\$202.50	1
Camp Evers Park	1.1.5	Parking	Repair or correct slope of parking space and access aisle to max 2.08% in any direction	\$2,187.50	each	1	\$2,187.50	1
Camp Evers Park	1.1.6	Parking	Resurface stalls and access aisles to eliminate gaps and cracks	\$2,000.00	each	1	\$2,000.00	1
Camp Evers Park	1.1.7	Parking	Raise sign to min 60" above the ground	\$0.00	staff time	0	\$0.00	1
Camp Evers Park	1.2.1	Exterior Route	Establish protocols to maintain AR to be free of deteriorations	\$0.00	staff time	0	\$0.00	1
Camp Evers Park	1.2.2	Exterior Route	Repair, bevel, or ramp CIL along AR	\$68.75	each	3	\$206.25	1
Camp Evers Park	1.2.3	Exterior Route	Correct or fill gaps along AR	\$68.75	each	2	\$137.50	1
Camp Evers Park	1.2.4	Exterior Route	Correct or repair sidewalk cross slope along AR to max 2.08%	\$87.50	sq ft	100	\$8,750.00	1
Camp Evers Park	1.2.5	Exterior Route	Widen AR at the turn to be 42" wide and 48" deep at the turn	\$16.00	sq ft	8	\$128.00	1
Camp Evers Park	1.10.1	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the grills	\$48.00	lin ft	25	\$1,200.00	2
Camp Evers Park	1.10.2	Park Site	See recommendations in section 1.13 for corrections to ramp to fishing area	\$0.00	n/a	0	\$0.00	2
Camp Evers Park	1.10.3	Park Site	Lower 25% of the railing to max 34" above the deck surface at the fishing area	\$785.00	each	1	\$785.00	2
Camp Evers Park	1.10.4	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the picnic tables	\$48.00	lin ft	25	\$1,200.00	2
Camp Evers Park	1.13.1	Ramp	Shorten ramp run to max 30' or a max of 30" rise	\$4,650.00	each	1	\$4,650.00	1
Camp Evers Park	1.13.2	Ramp	Correct slope of ramp to max 8.33%	\$87.50	sq ft	25	\$2,187.50	1
Camp Evers Park	1.13.3	Ramp	Correct ramp cross slope to max 2.08%	\$87.50	sq ft	75	\$6,562.50	1
Camp Evers Park	1.13.4	Ramp	Repair surface of ramp landing to be free of gaps and CIL	\$625.00	each	1	\$625.00	1
Camp Evers Park	1.13.5	Ramp	Repair slope on ramp landing to max 2.08% in any direction	\$87.50	sq ft	25	\$2,187.50	1
Camp Evers Park	1.13.6	Ramp	Enlarge landing on ramp to 60" by 60"	\$625.00	each	1	\$625.00	1
Camp Evers Park	1.13.7	Ramp	Install rail along bottom edge of ramp that prevents a 4" sphere from passing through	\$375.00	each	1	\$375.00	1
<a href="#">City Hall, Police</a>	1.1.1	Parking - Police	Repaint stalls and access aisles to be 9' and 5' each	\$52.50	each	2	\$105.00	1
City Hall, Police	1.1.2	Parking - Police	Add one van parking sign to one accessible stall and repaint stall and access aisle to 12' and 5' or 9' and 8'	\$202.50	each	1	\$202.50	1
City Hall, Police	1.1.3	Parking - Police	Acquire and mount at appropriate heights and locations compliant reflectorized accessible parking signs for all the stalls	\$150.00	each	1	\$150.00	1
City Hall, Police	1.1.4	Parking - Police	Raise existing accessible parking signs so the lowest end of bottom sign is min 60" aff or 80" aff if along EAR	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.1.1	Parking - City Hall	Repair or correct slope of parking space and access aisle to max 2.08% in any direction	\$2,187.50	each	1	\$2,187.50	1
City Hall, Police	1.1.2	Parking - City Hall	Raise existing accessible parking signs so the lowest end of bottom sign is min 60" aff or 80" aff if along EAR	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.1.3	Parking - City Hall	Acquire and mount at appropriate heights and locations compliant reflectorized accessible parking signs for all the stalls where indicated	\$150.00	each	2	\$300.00	1
City Hall, Police	1.2.1	Exterior Route	Create lined cross walk where pedestrian pathway crosses through vehicular traffic as a smart practice	\$262.50	each	1	\$262.50	1
City Hall, Police	1.2.2	Exterior Route	Install compliant detectable warning at curb ramps as a smart practice	\$235.00	each	1	\$235.00	1
City Hall, Police	1.2.3	Exterior Route	Create a level landing at the top of the curb ramp max slope 2.085, 36" deep and as wide as ramp	\$87.50	sq ft	25	\$2,187.50	1
City Hall, Police	1.2.4	Exterior Route	Correct slope of curb ramp side flares to max 8.33%	\$725.00	each	1	\$725.00	1
City Hall, Police	1.2.5	Exterior Route	Correct or repair AR to car garage to be max 5% slope, or treat as a ramp and provide handrails for routes between 5% and 8.33%	\$4,650.00	each	1	\$4,650.00	1
City Hall, Police	1.2.6	Exterior Route	Repair, bevel, or ramp CIL along AR	\$68.75	each	1	\$68.75	1

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
City Hall, Police	1.2.1	Stairs	Install handrails on both sides of stairway, mounted 34" to 38" aff with top and bottom extensions and having a 1.25" – 2" in diameter, or a non-circular grip that has a perimeter dimension of 4"- 6.25" max	\$700.00	each	1	\$700.00	1
City Hall, Police	1.2.2	Stairs	Correct tread depth on stairs so they are 11" minimum and consistent, leave as is if technically infeasible	\$288.75	each	14	\$4,042.50	1
City Hall, Police	1.2.3	Stairs	Install detectable warning strip on top tread of each stairway as a smart practice	\$150.00	each	1	\$150.00	1
City Hall, Police	1.2.4	Stairs	Correct riser heights on stairs to consistent height between 4" to 7", leave as is if technically infeasible	\$288.75	each	14	\$4,042.50	1
City Hall, Police	1.2.1	Ramp	Correct or repair landing slope to max 2.08% in any direction	\$87.50	sq ft	25	\$2,187.50	1
City Hall, Police	1.2.2	Ramp	Enlarge landing on ramp where directions change to 60" by 72"	\$625.00	each	3	\$1,875.00	1
City Hall, Police	1.2.3	Ramp	Replace or remount handrails to 34" to 38" aff with compliant handrail extensions	\$700.00	each	1	\$700.00	1
City Hall, Police	1.3.1	Exterior Signage	Mount signage at entrance designating it as accessible	\$150.00	each	1	\$150.00	1
City Hall, Police	1.4.1	Exterior Doors - Police	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	2	\$2,500.00	2
City Hall, Police	1.4.2	Exterior Doors - Police	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.4.3	Exterior Doors - Police	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	3	\$6,562.50	2
City Hall, Police	1.4.4	Exterior Doors - Police	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	7	\$481.25	2
City Hall, Police	1.4.5	Exterior Doors - Police	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.4.6	Exterior Doors - Police	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.4.7	Exterior Doors - Police	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	3	\$2,970.00	2
City Hall, Police	1.4.8	Exterior Doors - Police	Upon renovation; make above corrections to employee only doors	\$0.00	n/a	0	\$0.00	2
City Hall, Police	1.4.1	Exterior Doors - City Hall	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.4.2	Exterior Doors - City Hall	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	3	\$3,750.00	1
City Hall, Police	1.4.3	Exterior Doors - City Hall	For all doors along the public circulation route, correct or repair CIL at doorway landing to max .25" for level CFS	\$68.75	each	1	\$68.75	1
City Hall, Police	1.4.4	Exterior Doors - City Hall	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	2	\$4,375.00	1
City Hall, Police	1.4.5	Exterior Doors - City Hall	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	11	\$756.25	1
City Hall, Police	1.4.6	Exterior Doors - City Hall	For all doors along the public circulation route, replace thresholds at exterior doors with ADA thresholds	\$181.25	each	2	\$362.50	1
City Hall, Police	1.4.7	Exterior Doors - City Hall	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	1	\$367.50	1
City Hall, Police	1.4.8	Exterior Doors - City Hall	For all doors along the public circulation route, inspect, adjust, and maintain 8.5 lbf to open exterior doors as a smart practice	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.4.9	Exterior Doors - City Hall	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	5	\$4,950.00	1
City Hall, Police	1.4.10	Exterior Doors - City Hall	Upon renovation; make above corrections to employee only doors	\$0.00	n/a	0	\$0.00	1
City Hall, Police	1.6.1	Interior Doors - Police	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	20	\$25,000.00	2
City Hall, Police	1.6.2	Interior Doors - Police	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
City Hall, Police	1.6.3	Interior Doors - Police	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	1	\$2,187.50	2
City Hall, Police	1.6.4	Interior Doors - Police	For all doors along the public circulation route, replace doors with doors having 32" clear width where indicated	\$1,980.00	each	7	\$13,860.00	2
City Hall, Police	1.6.5	Interior Doors - Police	For all doors along the public circulation route, replace doors with ones having 36" clear width at recessed doors	\$1,980.00	each	3	\$5,940.00	2
City Hall, Police	1.6.6	Interior Doors - Police	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	5	\$1,837.50	2
City Hall, Police	1.6.7	Interior Doors - Police	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open interior doors	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.6.8	Interior Doors - Police	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.6.9	Interior Doors - Police	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	7	\$6,930.00	2
City Hall, Police	1.6.10	Interior Doors - Police	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	2
City Hall, Police	1.7.1	Interior Route - Police	Stairs only to squad room, leave as is, employee area only; reassign duties if an employee with a disability requires access here	\$0.00	n/a	0	\$0.00	2
City Hall, Police	1.7.2	Interior Route - Police	Repair, bevel or ramp CIL along AR	\$4,650.00	each	1	\$4,650.00	2
City Hall, Police	1.7.3	Interior Route - Police	Lower operating mechanisms along the interior AR to max 48" aff to the highest operable part	\$250.00	each	3	\$750.00	2
City Hall, Police	1.7.4	Interior Route - Police	Replace hardware on operable parts to not require tight pinch or grasp	\$100.00	each	1	\$100.00	2
City Hall, Police	1.7.5	Interior Route - Police	Remove, or relocate storage in CFS at fixtures and operable parts along the AR	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.7.6	Interior Route - Police	Lower 36" wide segment of service counter to max 34" aff, in the alternative, train staff to come out from around the counter to provide customer service	\$785.00	each	1	\$785.00	2
City Hall, Police	1.7.1	Stairs - Police	Install detectable warning strip on top tread of each stairway as a smart practice	\$150.00	each	1	\$150.00	2
City Hall, Police	1.7.2	Stairs - Police	Install compliant handrail extensions at bottom of stair run	\$700.00	each	1	\$700.00	2
City Hall, Police	1.7.3	Stairs - Police	Replace or remount handrails to 34" to 38" aff	\$700.00	each	1	\$700.00	2
City Hall, Police	1.8.1	Public Spaces - Police	Relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.8.2	Public Spaces - Police	Relocate obstacles to create turning space in spaces indicated	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.8.3	Public Spaces - Police	Lower operating mechanisms in spaces indicated to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	2	\$500.00	2
City Hall, Police	1.8.4	Public Spaces - Police	Replace one table in break room with one having required knee and toe clearance	\$800.00	each	1	\$800.00	2
City Hall, Police	1.9.1	Employee Spaces - Police	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.9.2	Employee Spaces - Police	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60° in spaces indicated	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.9.3	Employee Spaces - Police	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	2
City Hall, Police	1.11.1	Restrooms - Police	Restrooms not accessible, acquire and mount signage directing patrons to accessible restroom where indicated	\$150.00	each	2	\$300.00	2
City Hall, Police	1.11.2	Restrooms - Police	Remount signage to max 48" to tactile characters	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.11.3	Restrooms - Police	Remount toilets to 17" to 18" from the side wall to centerline in lobby restroom	\$1,306.00	each	1	\$1,306.00	2
City Hall, Police	1.11.4	Restrooms - Police	Widen accessible toilet rooms to min. 60" clear width in lobby restroom	\$1,963.75	each	1	\$1,963.75	2
City Hall, Police	1.11.5	Restrooms - Police	Replace toilet seat, or re-set or replace toilet to 17" to 19" aff	\$1,306.00	each	1	\$1,306.00	2
City Hall, Police	1.11.6	Restrooms - Police	Remount rear grab bar behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in lobby restroom	\$281.25	each	1	\$281.25	2
City Hall, Police	1.11.7	Restrooms - Police	Lower mirror so reflective surface is max 40" aff in lobby restroom	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.11.8	Restrooms - Police	Remove or relocate storage in CFS at sink in lobby restroom	\$0.00	staff time	0	\$0.00	2

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
City Hall, Police	1.11.9	Restrooms - Police	Lower sinks to max 34" aff to front of rim in lobby restroom	\$1,700.00	each	1	\$1,700.00	2
City Hall, Police	1.14.1	Alarms - Police	Install audible and visual alarms in rooms and spaces where alarms have been installed since 1992	\$407.50	each	30	\$12,225.00	2
City Hall, Police	1.14.2	Alarms - Police	Upon renovation install audible and visual alarms in all rooms and spaces	\$373.75	each	3	\$1,121.25	2
City Hall, Police	1.15.1	Interior Signage - Police	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.15.2	Interior Signage - Police	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	2
City Hall, Police	1.15.3	Interior Signage - Police	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	10	\$1,500.00	2
City Hall, Police	1.6.1	Interior Doors - City Hall	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	5	\$6,250.00	1
City Hall, Police	1.6.2	Interior Doors - City Hall	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.6.3	Interior Doors - City Hall	For all doors along the public circulation route, replace doors ones having 32" clear width where indicated	\$1,980.00	each	3	\$5,940.00	1
City Hall, Police	1.6.4	Interior Doors - City Hall	For all doors along the public circulation route, repair, bevel, or ramp CILs at door entries to max .25"	\$155.00	inch	8	\$1,240.00	1
City Hall, Police	1.6.5	Interior Doors - City Hall	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	7	\$2,572.50	1
City Hall, Police	1.6.6	Interior Doors - City Hall	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open interior doors	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.6.7	Interior Doors - City Hall	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.6.8	Interior Doors - City Hall	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	7	\$6,930.00	1
City Hall, Police	1.7.1	Interior Route - City Hall	Create means of vertical access to all floors of the building	\$31,165.00	each	1	\$31,165.00	1
City Hall, Police	1.7.2	Interior Route - City Hall	See 1.15 for corrections to signage	\$0.00	n/a	0	\$0.00	1
City Hall, Police	1.7.3	Interior Route - City Hall	Lower operating mechanisms along the interior AR to max 48" aff to the highest operable part	\$250.00	each	1	\$250.00	1
City Hall, Police	1.7.4	Interior Route - City Hall	Replace hardware on panel with hardware that does not require tight pinch or grasp	\$100.00	each	1	\$100.00	1
City Hall, Police	1.7.5	Interior Route - City Hall	Lower 36" wide segment of service counters to max 34" aff	\$785.00	each	3	\$2,355.00	1
City Hall, Police	1.8.1	Public Spaces - City Hall	Relocate protruding objects in chambers or place cane detectable warning or bollard at foot of television	\$250.00	each	1	\$250.00	1
City Hall, Police	1.8.2	Public Spaces - City Hall	Provide a ramp for access to the council table	\$155.00	inch	7	\$1,085.00	1
City Hall, Police	1.8.3	Public Spaces - City Hall	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.8.4	Public Spaces - City Hall	Lower operating mechanisms in spaces indicated to max 48" aff to highest operable part; leave as is if employee only operated	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.8.5	Public Spaces - City Hall	Provide alternative to podium that is usable by a person using a wheelchair	\$800.00	each	1	\$800.00	1
City Hall, Police	1.8.6	Public Spaces - City Hall	Lower sink height to max 34" aff	\$1,700.00	each	1	\$1,700.00	1
City Hall, Police	1.9.1	Employee Spaces - City Hall	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.9.2	Employee Spaces - City Hall	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.9.3	Employee Spaces - City Hall	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	1
City Hall, Police	1.11.1	Restrooms - Multiple Users - Council Chambers	Lower sinks to max 34" aff to front of rim in both	\$1,700.00	each	2	\$3,400.00	1

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
City Hall, Police	1.11.2	Restrooms - Multiple Users - Council Chambers	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	1
City Hall, Police	1.11.3	Restrooms - Multiple Users - Council Chambers	Lower hooks in accessible stalls to max 48" aff in both	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.4	Restrooms - Multiple Users - Council Chambers	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
City Hall, Police	1.11.5	Restrooms - Multiple Users - Council Chambers	Replace stall hardware on exterior with hardware operable without a tight pinch or grasp in both	\$100.00	each	2	\$200.00	1
City Hall, Police	1.11.6	Restrooms - Multiple Users - Council Chambers	Remount toilet paper dispenser max 7" to 9" from front of toilet, 15" to 48" aff and min 12" above or 1.5" below grab bar in both	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.7	Restrooms - Multiple Users - Council Chambers	Remount toilets to 17" to 18" from the side wall to centerline in both	\$1,306.00	each	2	\$2,612.00	1
City Hall, Police	1.11.8	Restrooms - Multiple Users - Council Chambers	Replace signage with compliant signage mounted in compliant location at women's	\$150.00	each	1	\$150.00	1
City Hall, Police	1.11.9	Restrooms - Multiple Users - Council Chambers	Remount side grab bar to max 12" from the rear wall at the close end and min 54" on the far end, and 33" to 36" aff in women's	\$281.25	each	1	\$281.25	1
City Hall, Police	1.11.10	Restrooms - Multiple Users - Council Chambers	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in women's	\$211.25	each	1	\$211.25	1
City Hall, Police	1.11.11	Restrooms - Multiple Users - Council Chambers	Relocate tampon dispenser to have required CFS outside of stall door swing	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.1	Restrooms - Multiple Users - City Hall	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	1
City Hall, Police	1.11.2	Restrooms - Multiple Users - City Hall	Lower hooks in accessible stalls to max 48" aff in both	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.3	Restrooms - Multiple Users - City Hall	Remount side grab bar to max 12" from the rear wall at the close end and min 54" on the far end, and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
City Hall, Police	1.11.4	Restrooms - Multiple Users - City Hall	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
City Hall, Police	1.11.5	Restrooms - Multiple Users - City Hall	Replace stall hardware on exterior with hardware operable without a tight pinch or grasp in both	\$100.00	each	2	\$200.00	1
City Hall, Police	1.11.6	Restrooms - Multiple Users - City Hall	Acquire and mount signage, including Braille and access symbol mounted on wall, latch side of door, 48" to baseline of lowest character and 60" to baseline of highest character in men's	\$150.00	each	1	\$150.00	1
City Hall, Police	1.11.7	Restrooms - Multiple Users - City Hall	Lower sinks to max 34" aff to front of rim in both	\$1,700.00	each	2	\$3,400.00	1
City Hall, Police	1.11.8	Restrooms - Multiple Users - City Hall	Remount toilets to 17" to 18" from the side wall to centerline in both	\$1,306.00	each	1	\$1,306.00	1
City Hall, Police	1.11.9	Restrooms - Multiple Users - City Hall	Adjust stall door to be self-closing in both	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.10	Restrooms - Multiple Users - City Hall	Lower mirror so reflective surface is max 40" aff in women's	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.11	Restrooms - Multiple Users - City Hall	Relocate garbage can to not obstruct CFS at toilet in women's	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.11.12	Restrooms - Multiple Users - City Hall	Replace toilet seat, or re-set or replace toilet to 17" to 19" aff in women's	\$1,306.00	each	1	\$1,306.00	1
City Hall, Police	1.11.13	Restrooms - Multiple Users - City Hall	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in women's	\$211.25	each	1	\$211.25	1
City Hall, Police	1.11.1	Restrooms - Single Users - City Hall	Restroom not accessible, acquire and mount signage directing patrons to accessible restroom until renovations occur	\$150.00	each	1	\$150.00	1
City Hall, Police	1.14.1	Alarms	Upon renovation install audible and visual alarms in all rooms and spaces	\$373.50	each	10	\$3,735.00	1
City Hall, Police	1.15.1	Interior Signage - City Hall	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.15.2	Interior Signage - City Hall	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	1
City Hall, Police	1.15.3	Interior Signage - City Hall	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	10	\$1,500.00	1



# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
<a href="#">Hocus Pocus Park</a>	1.2.1	Exterior Route	Create a curb ramp to be max running slope 8.33%, max cross slope 2.08%, having a top landing as wide as the ramp and 36" deep and side flares with a max slope 10% where indicated	\$1,062.50	each	1	\$1,062.50	1
Hocus Pocus Park	1.2.2	Exterior Route	Correct slope of curb top landing to max 2.08%	\$87.50	sq ft	25	\$2,187.50	1
Hocus Pocus Park	1.2.3	Exterior Route	Correct curb ramp slope to max 8.33%	\$725.00	each	1	\$725.00	1
Hocus Pocus Park	1.2.4	Exterior Route	Correct curb ramp cross slope to max 2.08%	\$725.00	each	1	\$725.00	1
Hocus Pocus Park	1.2.5	Exterior Route	Correct or repair sidewalk cross slope along AR to max 2.08%	\$87.50	sq ft	100	\$8,750.00	1
Hocus Pocus Park	1.2.6	Exterior Route	Correct or repair sidewalk running slope along AR to max 5%	\$87.50	sq ft	25	\$2,187.50	1
Hocus Pocus Park	1.4.1	Playground - Surface	Correct slope at both transfer systems to max 2.08% in every direction for CFS	\$87.50	sq ft	12	\$1,050.00	2
Hocus Pocus Park	1.4.2	Playground - Surface	Repair, bevel or ramp CILs within playground	\$68.75	each	2	\$137.50	2
Hocus Pocus Park	1.4.3	Playground - Surface	Fill and compact EWF surface so that it maintains its accessibility characteristics	\$5,000.00	each	1	\$5,000.00	2
Hocus Pocus Park	1.4.4	Playground - Surface	Frequently inspect and regularly maintain accessible portions of play area surface that are comprised of loose fill such as EWF so that surface is level with other surfaces	\$0.00	staff time	0	\$0.00	2
Hocus Pocus Park	1.4.5	Playground - Surface	Establish protocols for regular and frequent inspection and maintenance of accessible playground surface	\$0.00	staff time	0	\$0.00	2
Hocus Pocus Park	1.6.1	Playground - Ramps	Correct or repair ramp slope to be max 6.25%	\$87.50	sq ft	25	\$2,187.50	CO
Hocus Pocus Park	1.7.1	Playground - EPC	Lower reach range to overhead handles to max 28" aff for an individual seated on the deck as a smart practice	\$250.00	each	1	\$250.00	CO
Hocus Pocus Park	1.7.2	Playground - EPC	Adjust height of platform decks to max 8" for access to 3 more EPCs, in the alternative, install compliant transfer steps	\$1,000.00	each	1	\$1,000.00	CO
Hocus Pocus Park	1.7.3	Playground - EPC	Leave as is, remaining EPCs as the above correction will meet 50%	\$0.00	n/a	0	\$0.00	CO
Hocus Pocus Park	1.10.1	Park Site	Correct or fill gap at basketball court entry	\$68.75	each	1	\$68.75	2
Hocus Pocus Park	1.10.2	Park Site	Replace drinking fountain with a hi-lo bowl fountain	\$3,998.75	each	1	\$3,998.75	2
Hocus Pocus Park	1.10.3	Park Site	Correct or repair slope at bike racks to max 2.08% in any direction for level CFS	\$87.50	sq ft	12	\$1,050.00	2
Hocus Pocus Park	1.11.1	Shelters	Lower grill surface to max 34" aff at both	\$250.00	each	1	\$250.00	3
Hocus Pocus Park	1.11.2	Shelters	Replace 20% of the picnic tables with one with knee and toe clearance, 19" deep at 27" high and 24" deep at 9" high, with a 36" AR around the table as a smart practice at shelter near RR; in the alternative, leave as is and designate shelters at other sites in the City as accessible	\$800.00	each	1	\$800.00	CO
Hocus Pocus Park	1.12.1	Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors	\$0.00	staff time	0	\$0.00	1
Hocus Pocus Park	1.12.1	Restrooms	Remount signage on wall, latch side of the door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$0.00	staff time	0	\$0.00	1
Hocus Pocus Park	1.12.2	Restrooms	Remount sinks adjacent to partition 18" from side to center of fixture in both	\$1,700.00	each	2	\$3,400.00	1
Hocus Pocus Park	1.12.3	Restrooms	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	1
Hocus Pocus Park	1.12.4	Restrooms	Adjust timing of sink faucets to remain on for min 10 seconds in both	\$0.00	staff time	0	\$0.00	1
Hocus Pocus Park	1.12.5	Restrooms	Lower soap dispensers to max 44" aff for a forward reach over counter in both	\$0.00	staff time	0	\$0.00	1
Hocus Pocus Park	1.12.6	Restrooms	Replace toilet seat, or re-set or replace toilet to 17" to 19" aff in both	\$1,306.00	each	2	\$2,612.00	1
Hocus Pocus Park	1.12.7	Restrooms	Replace stall hardware with hardware operable without a tight pinch or grasp	\$100.00	each	2	\$200.00	1
Hocus Pocus Park	1.12.8	Restrooms	Relocate or recess hand dryers in both to not interfere with general circulation path, protrusions can't be greater than 4"	\$250.00	each	2	\$500.00	1
Hocus Pocus Park	1.12.9	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
Hocus Pocus Park	1.12.10	Restrooms	Widen AR to min 36" in women's	\$1,963.75	each	1	\$1,963.75	1
<a href="#">Lodato Park</a>	1.1.1	Parking	Create one or more 9' wide and 18' long accessible parking stalls, with one 5' adjacent access aisle, with proper signage and striping	\$1,135.00	each	1	\$1,135.00	CO
Lodato Park	1.2.1	Exterior Route	Create a curb ramp to be max running slope 8.33%, max cross slope 2.08%, having a top landing as wide as the ramp and 36" deep and side flares with a max slope 10%	\$1,062.50	each	1	\$1,062.50	CO
Lodato Park	1.2.2	Exterior Route	Replace AR with crushed and compacted stone or similar outdoor material	\$48.00	lin ft	200	\$9,600.00	CO
Lodato Park	1.2.3	Exterior Route	Repair, bevel, or ramp CIL along AR	\$68.75	each	5	\$343.75	CO

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Lodato Park	1.2.4	Exterior Route	Correct or repair cross slope along AR to max 2.08%	\$87.50	sq ft	125	\$10,937.50	CO
Lodato Park	1.2.5	Exterior Route	Correct or fill gaps along AR	\$68.75	each	5	\$343.75	CO
Lodato Park	1.2.6	Exterior Route	Correct or repair running slope along AR to max 5%	\$87.50	sq ft	50	\$4,375.00	CO
Lodato Park	1.2.7	Exterior Route	Maintain foliage along AR to not protrude	\$0.00	staff time	0	\$0.00	CO
Lodato Park	1.2.8	Exterior Route	AR is less than 60" wide, create a compliant 60" by 60" turning space every 200'	\$16.00	sq ft	100	\$1,600.00	CO
Lodato Park	1.2.9	Exterior Route	See section 1.10 for corrections to AR	\$0.00	n/a	0	\$0.00	CO
Lodato Park	1.10.1	Park Site	Relocate dog waste bags to be along the AR	\$0.00	staff time	0	\$0.00	CO
Lodato Park	1.10.2	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the bike rack	\$48.00	lin ft	50	\$2,400.00	CO
MacDorsa Park	1.1.1	Parking	Create one or more 9' accessible parking stalls, with one 5' adjacent access aisle, with proper signage and striping	\$1,135.00	each	1	\$1,135.00	1
MacDorsa Park	1.1.2	Parking	Repaint stalls and access aisles to be 9' and 5' each with high quality blue paint and symbols	\$52.50	each	1	\$52.50	1
MacDorsa Park	1.1.3	Parking	Add one van parking sign to one accessible stall and repaint stall and access aisle to 12' and 5' or 9' and 8'	\$202.50	each	1	\$202.50	1
MacDorsa Park	1.1.4	Parking	Repair or correct slope of parking space and access aisle to max 2.08% in any direction	\$2,187.00	each	2	\$4,374.00	1
MacDorsa Park	1.1.5	Parking	Acquire and mount at appropriate heights and locations compliant reflectorized accessible parking signs for all the stalls	\$5.00	each	2	\$10.00	1
MacDorsa Park	1.2.1	Exterior Route	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to Scotts House entries	\$48.00	lin ft	100	\$4,800.00	1
MacDorsa Park	1.2.2	Exterior Route	Relocate picnic table to be along AR	\$0.00	staff time	0	\$0.00	1
MacDorsa Park	1.2.3	Exterior Route	Repair, bevel, or ramp CIL along AR	\$155.00	inch	24	\$3,720.00	1
MacDorsa Park	1.2.4	Exterior Route	Correct or fill gaps along AR	\$68.75	each	1	\$68.75	1
MacDorsa Park	1.2.5	Exterior Route	Correct or repair sidewalk cross slope along AR to max 2.08%	\$87.50	sq ft	25	\$2,187.50	1
MacDorsa Park	1.2.6	Exterior Route	Correct or repair sidewalk running slope along AR to max 5%	\$87.50	sq ft	50	\$4,375.00	1
MacDorsa Park	1.2.7	Exterior Route	Create a compliant 60" by 60" turning space every 200' or every 400' with constant gradient	\$16.00	sq ft	50	\$800.00	1
MacDorsa Park	1.3.1	Playground - Entry	Repair or reset tiles to eliminate CIL and gaps	\$68.75	each	4	\$275.00	CO
MacDorsa Park	1.4.1	Playground - Surface	Fill and compact EWF surface so that it maintains its accessibility characteristics	\$5,000.00	each	1	\$5,000.00	CO
MacDorsa Park	1.4.2	Playground - Surface	Frequently inspect and regularly maintain accessible portions of play area surface that are comprised of loose fill such as EWF so that surface is level with other surfaces	\$0.00	staff time	0	\$0.00	CO
MacDorsa Park	1.4.3	Playground - Surface	Establish protocols for regular and frequent inspection and maintenance of accessible playground surface	\$0.00	staff time	0	\$0.00	CO
MacDorsa Park	1.5.1	Playground - Transfer System	See 1.3.1 for correction to tiles	\$0.00	n/a	0	\$0.00	CO
MacDorsa Park	1.8.1	Playground - GLPC	See 1.4.2 for correction to CIL at mats	\$0.00	n/a	0	\$0.00	CO
MacDorsa Park	1.10.1	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the horse shoes	\$48.00	lin ft	100	\$4,800.00	2
MacDorsa Park	1.10.2	Park Site	Lower counter, grill, and sink at grill counter to be max. 34" aff	\$785.00	each	3	\$2,355.00	2
MacDorsa Park	1.10.3	Park Site	Replace faucet controls with lever controls at grill counter	\$525.00	each	1	\$525.00	2
MacDorsa Park	1.10.4	Park Site	Relocate bike rack to be along AR	\$250.00	each	1	\$250.00	2
MacDorsa Park	1.10.5	Park Site	Replace drinking fountain with a hi-lo bowl fountain	\$3,998.75	each	1	\$3,998.75	2
MacDorsa Park	1.10.6	Park Site	Construct firm, stable, and slip resistant pads at least 36" by 48" adjacent to 20% of benches, and locate along an AR as a smart practice	\$115.00	each	1	\$115.00	2
MacDorsa Park	1.10.7	Park Site	Add surface fill to achieve 17" to 19" bench height as a smart practice	\$500.00	each	1	\$500.00	2
MacDorsa Park	1.10.8	Park Site	Relocate accessible picnic table to be along AR with a 36" AR around table as a smart practice	\$0.00	staff time	0	\$0.00	2
MacDorsa Park	1.11.1	Shelters	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to shelter	\$48.00	lin ft	100	\$4,800.00	CO
MacDorsa Park	1.11.2	Shelters	Repair, bevel or ramp CIL at shelter entry	\$155.00	inch	7	\$1,085.00	CO
MacDorsa Park	1.11.3	Shelters	Relocate table to provide 60" turning space in shelter interior	\$0.00	staff time	0	\$0.00	CO
MacDorsa Park	1.12.1	Interior Route	Widen AR to 36" wide at door passages if not an historic building	\$1,980.00	each	2	\$3,960.00	3

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
MacDorsa Park	1.12.1	Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	11	\$13,750.00	3
MacDorsa Park	1.12.2	Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	2	\$4,375.00	3
MacDorsa Park	1.12.3	Doors	For all doors along the public circulation route, replace doors with ones having 80" overhead and 32" clear width where indicated	\$1,980.00	each	10	\$19,800.00	3
MacDorsa Park	1.12.4	Doors	For all doors along the public circulation route, replace thresholds at exterior doors with ADA thresholds	\$181.25	each	4	\$725.00	3
MacDorsa Park	1.12.5	Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	9	\$3,307.50	3
MacDorsa Park	1.12.6	Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors as a smart practice	\$0.00	staff time	0	\$0.00	3
MacDorsa Park	1.12.1	Rooms	Relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	3
MacDorsa Park	1.12.2	Rooms	Leave as is, lack of access to upper level storage; correction may be technically infeasible	\$0.00	n/a	0	\$0.00	3
MacDorsa Park	1.12.3	Rooms	Raise obstructions to min 80", or pad object to prevent hazard in overhead clearance	\$250.00	each	1	\$250.00	3
MacDorsa Park	1.12.4	Rooms	Relocate obstacles to create turning space in spaces indicated if feasible	\$0.00	staff time	0	\$0.00	3
MacDorsa Park	1.12.5	Rooms	Lower sink height to max 34" aff	\$1,700.00	each	1	\$1,700.00	3
MacDorsa Park	1.12.1	Restrooms	Acquire and mount signage, including Braille and access symbol mounted on wall, latch side of door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$150.00	each	2	\$300.00	3
MacDorsa Park	1.12.2	Restrooms	Lower mirror so reflective surface is max 40" aff in both	\$0.00	staff time	0	\$0.00	3
MacDorsa Park	1.12.3	Restrooms	Remount sink so centerline is min 18" from side wall in both	\$1,700.00	each	2	\$3,400.00	3
MacDorsa Park	1.12.4	Restrooms	Adjust timing of sink faucets to remain on for min 10 seconds in both	\$0.00	staff time	0	\$0.00	3
MacDorsa Park	1.12.5	Restrooms	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	3
MacDorsa Park	1.12.6	Restrooms	Lower hooks in accessible stalls to max 48" aff in both	\$0.00	staff time	0	\$0.00	3
MacDorsa Park	1.12.7	Restrooms	Remount side grab bar to max 12" from the rear wall at the close end and min 54" on the far end, and 33" to 36" aff in both	\$281.25	each	2	\$562.50	3
MacDorsa Park	1.12.8	Restrooms	Replace stall hardware with hardware operable without a tight pinch or grasp and adjust stall door to be self-closing in both	\$100.00	each	2	\$200.00	3
MacDorsa Park	1.12.9	Restrooms	Lower urinal so that rim height is max 17" aff in men's	\$1,217.50	each	1	\$1,217.50	3
MacDorsa Park	1.12.10	Restrooms	Relocate urinal to have required CFS outside swing of stall door in men's	\$1,217.50	each	1	\$1,217.50	3
MacDorsa Park	1.12.11	Restrooms	Remount toilets to 17" to 18" from the side wall to centerline in both	\$1,306.00	each	2	\$2,612.00	3
MacDorsa Park	1.12.12	Restrooms	Widen accessible stalls to min. 60" clear width, 59" depth in men's	\$1,963.75	each	2	\$3,927.50	3
MacDorsa Park	1.12.13	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	3
MacDorsa Park	1.12.14	Restrooms	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in men's	\$211.25	each	2	\$422.50	3
MacDorsa Park	1.12.15	Restrooms	Correct or repair slope at sink to max 2.08% in any direction for level CFS in women's	\$87.50	sq ft	25	\$2,187.50	3
<a href="#">Public Works</a>	1.1.1	Parking	Create one or more 9' wide and 18' long accessible parking stalls, with one 5' adjacent access aisle, with proper signage and striping	\$1,135.00	each	1	\$1,135.00	3
Public Works	1.2.1	Ramp	Correct ramp landing slope to max 2.08% in any direction	\$87.50	sq ft	25	\$2,187.50	3
Public Works	1.2.2	Ramp	Remount handrails to 34" to 38" aff	\$250.00	each	1	\$250.00	3
Public Works	1.2.3	Ramp	Adjust handrails to have min 1.5" clearance along length of run	\$250.00	each	1	\$250.00	3
Public Works	1.2.4	Ramp	Replace handrails with ones that are not corroded	\$700.00	each	1	\$700.00	3
Public Works	1.3.1	Exterior Signage	Mount signage at entrance designating it as accessible	\$150.00	each	1	\$150.00	3
Public Works	1.4.1	Exterior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	3



# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Public Works	1.4.2	Exterior Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	1	\$2,187.50	3
Public Works	1.4.3	Exterior Doors	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	6	\$412.50	3
Public Works	1.4.4	Exterior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	2	\$735.00	3
Public Works	1.4.5	Exterior Doors	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	3	\$2,970.00	3
Public Works	1.4.6	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors as a smart practice	\$0.00	staff time	0	\$0.00	3
Public Works	1.4.7	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	3
Public Works	1.4.8	Exterior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	3
Public Works	1.6.1	Interior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	3
Public Works	1.6.2	Interior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	4	\$5,000.00	3
Public Works	1.6.3	Interior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	15	\$5,512.50	3
Public Works	1.6.4	Interior Doors	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	2	\$1,980.00	3
Public Works	1.6.5	Interior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	3
Public Works	1.6.6	Interior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	3
Public Works	1.8.1	Public Spaces	Relocate protruding objects in spaces indicated or place cane detectable warning or bollard at foot of protrusions	\$250.00	each	1	\$250.00	3
Public Works	1.8.2	Public Spaces	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	3
Public Works	1.8.3	Public Spaces	Lower operating mechanisms in spaces indicated to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	2	\$500.00	3
Public Works	1.8.4	Public Spaces	Lower 36" wide segment of service counter to max 34" aff	\$785.00	each	1	\$785.00	3
Public Works	1.9.1	Employee Spaces	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	3
Public Works	1.9.2	Employee Spaces	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	3
Public Works	1.9.3	Employee Spaces	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	3
Public Works	1.11.1	Restrooms	Acquire and mount signage, including Braille and access symbol mounted on wall, latch side of door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$150.00	each	1	\$150.00	3
Public Works	1.11.2	Restrooms	Lower mirror so reflective surface is max 40" aff	\$0.00	staff time	0	\$0.00	3
Public Works	1.11.3	Restrooms	Insulate exposed pipes under one sink	\$55.00	each	1	\$55.00	3
Public Works	1.11.4	Restrooms	Lower urinal so that rim height is max 17" aff	\$1,217.50	each	1	\$1,217.50	3
Public Works	1.11.5	Restrooms	Create a wheelchair accessible stall with grab bars and fixtures mounted in correct locations and at correct heights	\$3,936.25	each	1	\$3,936.25	3
Public Works	1.11.6	Restrooms	Relocate or recess towel dispenser to not interfere with general circulation path, protrusions can't be greater than 4"	\$250.00	each	1	\$250.00	3
Public Works	1.11.7	Restrooms	Create accessible shower in restroom	\$4,881.25	each	1	\$4,881.25	3
Public Works	1.11.1	Restrooms	Acquire and mount signage, including Braille and access symbol mounted on wall, latch side of door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$150.00	each	1	\$150.00	3
Public Works	1.11.2	Restrooms	Remount side grab bar to max 12" from the rear wall at the close end and min 54" on the far end, and 33" to 36" aff	\$281.25	each	1	\$281.25	3

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Public Works	1.11.3	Restrooms	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit	\$211.25	each	1	\$211.25	3
Public Works	1.11.4	Restrooms	Remount toilet paper dispenser max 7" to 9" from front of toilet, 15" to 48" aff and min 12" above or 1.5" below grab bar	\$0.00	staff time	0	\$0.00	3
Public Works	1.11.5	Restrooms	Lower mirror so reflective surface is max 40" aff	\$0.00	staff time	0	\$0.00	3
Public Works	1.11.6	Restrooms	Remove under sink cabinets to provide knee and toe clearances under sinks and insulate exposed pipes	\$840.00	each	1	\$840.00	3
Public Works	1.11.7	Restrooms	Replace faucet controls with lever controls	\$525.00	each	1	\$525.00	3
Public Works	1.11.8	Restrooms	Lower hooks in accessible stalls to max 48" aff	\$0.00	staff time	0	\$0.00	3
Public Works	1.11.9	Restrooms	Relocate paper towel dispenser to be max 48" aff to the highest operable part and in an area providing required CFS	\$250.00	each	1	\$250.00	3
Public Works	1.12.1	Kitchen	Relocate table to provide required CFS at sink	\$0.00	staff time	0	\$0.00	3
Public Works	1.12.2	Kitchen	Remove under sink cabinets to provide knee and toe clearances under sinks and insulate exposed pipes	\$840.00	each	1	\$840.00	3
Public Works	1.12.3	Kitchen	Replace oven with one having controls on front of unit	\$2,000.00	each	1	\$2,000.00	3
Public Works	1.12.4	Kitchen	Secure edges of carpeting or mats to prevent trip hazard	\$100.00	each	1	\$100.00	3
Public Works	1.12.5	Kitchen	Lower operating mechanisms to max 44" aff to highest operable part for a forward reach over the sink; leave as is if employee only operated	\$0.00	staff time	0	\$0.00	3
Public Works	1.14.1	Alarms	Upon renovation install audible and visual alarms in all rooms and spaces	\$407.50	each	20	\$8,150.00	3
Public Works	1.15.1	Interior Signage	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	3
Public Works	1.15.2	Interior Signage	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	3
Public Works	1.15.3	Interior Signage	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	4	\$600.00	3
<a href="#">Scotts Valley Community Center</a>	1.1.1	Parking	Repaint access aisle with required "no parking" designation	\$52.50	each	4	\$210.00	1
Scotts Valley Community Center	1.1.2	Parking	Repair or correct slope of parking spaces and access aisle to max 2.08% in any direction	\$2,187.50	each	5	\$10,937.50	1
Scotts Valley Community Center	1.1.3	Parking	Relocate accessible stalls so sewer grate does not interfere with surface of stalls	\$262.50	each	1	\$262.50	1
Scotts Valley Community Center	1.1.4	Parking	Acquire and mount at appropriate heights and locations accessible parking signs for all the stalls	\$150.00	each	4	\$600.00	1
Scotts Valley Community Center	1.2.1	Exterior Route	Widen existing perpendicular curb ramp to min 48"	\$725.00	each	1	\$725.00	1
Scotts Valley Community Center	1.2.2	Exterior Route	Correct curb ramp slope to max 8.33%	\$725.00	each	1	\$725.00	1
Scotts Valley Community Center	1.2.3	Exterior Route	Install compliant detectable warning at curb ramps and transitions from walkways to vehicular ways as a smart practice	\$235.00	each	2	\$470.00	1
Scotts Valley Community Center	1.2.4	Exterior Route	Correct slope of curb ramp side flares to max 8.33%	\$725.00	each	2	\$1,450.00	1
Scotts Valley Community Center	1.2.5	Exterior Route	Create a level landing, max 2.08%, at the bottom of the parallel curb ramp	\$87.50	sq ft	16	\$1,400.00	1
Scotts Valley Community Center	1.2.6	Exterior Route	Maintain plant growth so it does not obstruct surface of AR	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.3.1	Exterior Signage	Mount signage at entrance designating it as accessible	\$150.00	each	1	\$150.00	1
Scotts Valley Community Center	1.4.1	Exterior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.4.2	Exterior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	6	\$7,500.00	1
Scotts Valley Community Center	1.4.3	Exterior Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	5	\$10,937.50	1
Scotts Valley Community Center	1.4.4	Exterior Doors	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	8	\$550.00	1
Scotts Valley Community Center	1.4.5	Exterior Doors	For all doors along the public circulation route, replace thresholds at exterior doors with ADA thresholds	\$181.25	each	2	\$362.50	1

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Scotts Valley Community Center	1.4.6	Exterior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	2	\$735.00	1
Scotts Valley Community Center	1.4.7	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.4.8	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.4.9	Exterior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	1
Scotts Valley Community Center	1.6.1	Interior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	2	\$2,500.00	1
Scotts Valley Community Center	1.6.2	Interior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.6.3	Interior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	3	\$1,102.50	1
Scotts Valley Community Center	1.6.4	Interior Doors	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	1	\$990.00	1
Scotts Valley Community Center	1.6.5	Interior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open interior doors	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.6.6	Interior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	1
Scotts Valley Community Center	1.7.1	Interior Route	Lower operating mechanisms along the interior AR to max 48" aff to the highest operable part	\$250.00	each	1	\$250.00	1
Scotts Valley Community Center	1.7.2	Interior Route	Relocate dimmer switch to have required CFS outside swing of door	\$250.00	each	1	\$250.00	1
Scotts Valley Community Center	1.7.3	Interior Route	Replace drinking fountain with hi-lo bowl and assure spout heights meet technical standards	\$3,998.75	each	1	\$3,998.75	1
Scotts Valley Community Center	1.7.4	Interior Route	Widen alcove to provide 32" clear width centered on the low bowl of the new fountain	\$1,100.00	each	1	\$1,100.00	1
Scotts Valley Community Center	1.7.5	Interior Route	Mount compliant signage at all doors along the egress route	\$150.00	each	12	\$1,800.00	1
Scotts Valley Community Center	1.8.1	Public Spaces	Relocate obstacles to create AR and turning space through closet in great room	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.8.2	Public Spaces	Repair, bevel or ramp CIL in rooms indicated	\$155.00	inch	8	\$1,240.00	1
Scotts Valley Community Center	1.8.3	Public Spaces	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.8.4	Public Spaces	Lower operating mechanisms to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	1	\$250.00	1
Scotts Valley Community Center	1.8.5	Public Spaces	Replace knob hardware with hardware that does not require a tight pinch or grasp	\$100.00	each	1	\$100.00	1
Scotts Valley Community Center	1.9.1	Employee Spaces	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.9.2	Employee Spaces	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.9.3	Employee Spaces	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	1
Scotts Valley Community Center	1.11.1	Restrooms	Remount signage on wall, latch side of the door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.11.2	Restrooms	Insulate exposed pipes under one sink in in both	\$55.00	each	2	\$110.00	1
Scotts Valley Community Center	1.11.3	Restrooms	Lower hooks in accessible stalls to max 48" aff in both	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.11.4	Restrooms	Widen accessible stalls to min. 60" clear width, 59" depth in both	\$1,963.75	each	2	\$3,927.50	1
Scotts Valley Community Center	1.11.5	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
Scotts Valley Community Center	1.11.6	Restrooms	Replace stall hardware on door exterior with hardware operable without a tight pinch or grasp in both	\$100.00	each	2	\$200.00	1
Scotts Valley Community Center	1.11.7	Restrooms	Lower urinal so that flush control height is max 44" aff in men's	\$1,217.50	each	1	\$1,217.50	1
Scotts Valley Community Center	1.11.8	Restrooms	Remount toilet to 17" to 18" from the side wall to centerline in both	\$1,306.00	each	2	\$2,612.00	1
Scotts Valley Community Center	1.11.9	Restrooms	Remount toilet paper dispenser max 7" to 9" from front of toilet, 15" to 48" aff and min 12" above or 1.5" below grab bar in both	\$0.00	staff time	0	\$0.00	1

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Scotts Valley Community Center	1.11.10	Restrooms	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in women's	\$211.25	each	1	\$211.25	1
Scotts Valley Community Center	1.11.11	Restrooms	Relocate dispensers to have required CFS outside of stall door swing in women's	\$250.00	each	2	\$500.00	1
Scotts Valley Community Center	1.12.1	Kitchen	Relocate sink island to create required 36" AR throughout	\$2,485.00	each	1	\$2,485.00	1
Scotts Valley Community Center	1.12.2	Kitchen	Lower sinks to max 34" aff to front of rim	\$1,700.00	each	1	\$1,700.00	1
Scotts Valley Community Center	1.12.3	Kitchen	Remove under sink cabinets to provide knee and toe clearances under sinks and insulate exposed pipes	\$840.00	each	1	\$840.00	1
Scotts Valley Community Center	1.12.4	Kitchen	Replace oven with one having controls on the front of the unit	\$2,000.00	each	1	\$2,000.00	1
Scotts Valley Community Center	1.12.5	Kitchen	Relocate protruding objects in kitchen or place cane detectable warning or bollard at foot of protrusions	\$250.00	each	1	\$250.00	1
Scotts Valley Community Center	1.12.6	Kitchen	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.12.7	Kitchen	Lower 36" wide segment of service counter to max 34" aff	\$785.00	each	1	\$785.00	1
Scotts Valley Community Center	1.12.8	Kitchen	Lower operating mechanisms in kitchen to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	2	\$500.00	1
Scotts Valley Community Center	1.12.9	Kitchen	See doors above for egress correction	\$0.00	n/a	0	\$0.00	1
Scotts Valley Community Center	1.14.1	Alarms	Upon renovation install audible and visual alarms in all rooms and spaces	\$407.50	each	12	\$4,890.00	1
Scotts Valley Community Center	1.15.1	Interior Signage	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.15.2	Interior Signage	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	1
Scotts Valley Community Center	1.15.3	Interior Signage	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	4	\$600.00	1
Scotts Valley Community Center	1.16.1	Park Site	Create more raised plots at community garden to satisfy 20% of total accessible as a smart practice	\$500.00	each	2	\$1,000.00	1
<a href="#">Scotts Valley Dog Park</a>	1.1.1	Parking	Repaint stalls to be 18' long and 9' wide and access aisles 5' each with a high quality blue paint	\$52.50	each	3	\$157.50	2
Scotts Valley Dog Park	1.1.2	Parking	Add one van parking sign to one accessible stall and repaint stall and access aisle to 12' and 5' or 9' and 8'	\$202.50	each	1	\$202.50	2
Scotts Valley Dog Park	1.1.3	Parking	Paint access aisles with diagonal lines spaced 36" on center in a contrasting color to the surface and "NO PARKING" painted on aisle, min of 12" high	\$52.50	each	3	\$157.50	2
Scotts Valley Dog Park	1.1.4	Parking	Paint stall with the symbol of access 36" by 36" and centered in space	\$52.50	each	3	\$157.50	2
Scotts Valley Dog Park	1.1.5	Parking	Acquire and mount at appropriate heights and locations accessible parking signs for all the stalls	\$150.00	each	1	\$150.00	2
Scotts Valley Dog Park	1.1.6	Parking	Repair, bevel, or ramp CIL from parking to AR	\$68.75	each	1	\$68.75	2
Scotts Valley Dog Park	1.1.7	Parking	Reconfigure stall placement to avoid cars blocking adjacent AR	\$262.50	each	1	\$262.50	2
Scotts Valley Dog Park	1.10.1	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to information sign	\$48.00	lin ft	20	\$960.00	2
Scotts Valley Dog Park	1.10.2	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to dog park	\$48.00	lin ft	75	\$3,600.00	2
Scotts Valley Dog Park	1.10.3	Park Site	Replace surface in dog park with crushed and compacted stone or similar outdoor material	\$50,000.00	each	1	\$50,000.00	2
Scotts Valley Dog Park	1.10.4	Park Site	Lower latch at dog park to max 48" aff and assure it is accessible from both sides of the gate	\$250.00	each	1	\$250.00	2
Scotts Valley Dog Park	1.10.5	Park Site	Maintain entries at dog park to be free of build-up	\$0.00	staff time	0	\$0.00	2
<a href="#">Senior Center</a>	1.1.1	Parking	Repaint stalls and access aisles with blue paint including compliant icon	\$52.50	each	2	\$105.00	2
Senior Center	1.1.2	Parking	Repair or correct slope of parking spaces and access aisles to max 2.08% in any direction	\$2,187.50	each	3	\$6,562.50	2
Senior Center	1.1.3	Parking	Replace existing signage with compliant signage mounted at compliant height	\$150.00	each	1	\$150.00	2
Senior Center	1.2.1	Exterior Route	Ramp steps for access to deck	\$4,650.00	each	1	\$4,650.00	2

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Senior Center	1.2.2	Exterior Route	Construct firm, stable, and slip resistant pads at least 36" by 48" adjacent to 20% of benches, and locate along an AR as a smart practice	\$115.00	each	1	\$115.00	2
Senior Center	1.2.3	Exterior Route	Correct slope of adjacent street surfaces to max 5%	\$87.50	sq ft	25	\$2,187.50	2
Senior Center	1.2.4	Exterior Route	Correct curb ramp cross slope to max 2.08%	\$725.00	each	2	\$1,450.00	2
Senior Center	1.2.5	Exterior Route	Correct curb ramp slope to max 8.33%	\$725.00	each	1	\$725.00	2
Senior Center	1.2.6	Exterior Route	Correct or fill gaps along AR	\$68.75	each	1	\$68.75	2
Senior Center	1.2.7	Exterior Route	Correct or repair sidewalk running slope along AR to max 5%	\$87.50	sq ft	50	\$4,375.00	2
Senior Center	1.3.1	Exterior Signage	Mount signage at inaccessible entrances directing patrons in wheelchairs to accessible entrance	\$150.00	each	1	\$150.00	2
Senior Center	1.3.2	Exterior Signage	Mount signage at entrance designating it as accessible	\$150.00	each	1	\$150.00	2
Senior Center	1.4.1	Exterior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2
Senior Center	1.4.2	Exterior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	2	\$2,500.00	2
Senior Center	1.4.3	Exterior Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	2	\$4,375.00	2
Senior Center	1.4.4	Exterior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated and remount between 34" to 48" aff	\$367.50	each	2	\$735.00	2
Senior Center	1.4.5	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors	\$0.00	staff time	0	\$0.00	2
Senior Center	1.4.6	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	2
Senior Center	1.4.7	Exterior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	2
Senior Center	1.6.1	Interior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2
Senior Center	1.6.2	Interior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	7	\$8,750.00	2
Senior Center	1.6.3	Interior Doors	For all doors along the public circulation route, widen doors to 32" for any doors indicated	\$1,980.00	each	2	\$3,960.00	2
Senior Center	1.6.4	Interior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	5	\$1,837.50	2
Senior Center	1.6.5	Interior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors as a smart practice	\$0.00	staff time	0	\$0.00	2
Senior Center	1.6.6	Interior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	2
Senior Center	1.8.1	Public Spaces	Relocate obstacles to create AR through main room	\$0.00	staff time	0	\$0.00	2
Senior Center	1.8.2	Public Spaces	Relocate protruding objects in spaces indicated or place cane detectable warning or bollard at foot of protrusions	\$250.00	each	3	\$750.00	2
Senior Center	1.8.3	Public Spaces	Provide ramp for access to stage in main room	\$4,650.00	each	1	\$4,650.00	2
Senior Center	1.8.4	Public Spaces	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	2
Senior Center	1.8.5	Public Spaces	Lower operating mechanisms in spaces indicated to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	3	\$750.00	2
Senior Center	1.8.6	Public Spaces	Replace hardware on operable parts to be able to be used without tight pinch or grasp	\$100.00	each	1	\$100.00	2
Senior Center	1.8.7	Public Spaces	Lower 36" wide segment of service counter to max 34" aff	\$785.00	each	1	\$785.00	2
Senior Center	1.8.8	Public Spaces	Replace drinking fountain with hi-lo bowl	\$3,998.75	each	1	\$3,998.75	2
Senior Center	1.9.1	Employee Spaces	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	2
Senior Center	1.9.2	Employee Spaces	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	2
Senior Center	1.9.3	Employee Spaces	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	2



# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Senior Center	1.11.1	Restrooms	Acquire and mount signage, including Braille and access symbol mounted on wall, latch side of door, 48" to baseline of Braille characters and 60" to baseline of highest character at both	\$150.00	each	2	\$300.00	2
Senior Center	1.11.2	Restrooms	Lower sinks to max 34" aff to front of rim in both	\$1,700.00	each	2	\$3,400.00	2
Senior Center	1.11.3	Restrooms	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	2
Senior Center	1.11.4	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	2
Senior Center	1.11.5	Restrooms	Replace stall hardware with hardware operable without a tight pinch or grasp and adjust stall doors to be self-closing in both	\$100.00	each	2	\$200.00	2
Senior Center	1.11.6	Restrooms	See doors above for correction to egress	\$0.00	n/a	0	\$0.00	2
Senior Center	1.11.7	Restrooms	Lower mirror so reflective surface is max 40" aff in both	\$0.00	staff time	0	\$0.00	2
Senior Center	1.11.8	Restrooms	Relocate bench to create required CFS at restroom elements in men's	\$250.00	each	1	\$250.00	2
Senior Center	1.11.9	Restrooms	Lower urinal so that rim height is max 17" aff in men's	\$1,217.50	each	1	\$1,217.50	2
Senior Center	1.11.10	Restrooms	Lower paper towel dispenser in women's and hooks in both to max 48" to highest operable part	\$250.00	each	1	\$250.00	2
Senior Center	1.11.11	Restrooms	Remount side grab bar to max 12" from the rear wall at the close end and min 54" on the far end, and 33" to 36" aff in both	\$281.25	each	2	\$562.50	2
Senior Center	1.11.12	Restrooms	Relocate or recess towel dispenser to not interfere with general circulation path in men's, protrusions can't be greater than 4"	\$250.00	each	1	\$250.00	2
Senior Center	1.11.13	Restrooms	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in women's	\$211.25	each	1	\$211.25	2
Senior Center	1.11.14	Restrooms	Remount toilet paper dispenser max 7" to 9" from front of toilet, 15" to 48" aff and min 12" above or 1.5" below grab bar in women's	\$0.00	staff time	0	\$0.00	2
Senior Center	1.11.15	Restrooms	Relocate soap dispenser to have required 30"x48" CFS in women's	\$0.00	staff time	0	\$0.00	2
Senior Center	1.11.1	Restrooms	Restroom not accessible, acquire and mount signage directing patrons to accessible restroom	\$150.00	each	1	\$150.00	2
Senior Center	1.12.1	Kitchen	Widen clearance between counters to min 60", if feasible	\$785.00	each	1	\$785.00	2
Senior Center	1.12.2	Kitchen	Remove base cabinet and lower sink height to max 34" aff	\$2,485.00	each	1	\$2,485.00	2
Senior Center	1.12.3	Kitchen	Raise exhaust hood to min 80", or pad object to prevent hazard in overhead clearance	\$250.00	each	1	\$250.00	2
Senior Center	1.12.4	Kitchen	Relocate obstructions in CFS of operable parts	\$0.00	staff time	0	\$0.00	2
Senior Center	1.12.5	Kitchen	Lower operating mechanisms in kitchen to max 48" aff to highest operable part	\$250.00	each	1	\$250.00	2
Senior Center	1.14.1	Alarms	Upon renovation install audible and visual alarms in all rooms and spaces	\$407.50	each	11	\$4,482.50	2
Senior Center	1.15.1	Interior Signage	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	2
Senior Center	1.15.2	Interior Signage	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	2
Senior Center	1.15.3	Interior Signage	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	5	\$750.00	2
Siltanen Park	1.1.2	Parking	Repaint stalls and add access aisles to be 9' and 5' each	\$52.50	each	12	\$630.00	1
Siltanen Park	1.1.3	Parking	Repair or correct slope of parking spaces and access aisles to max 2.08% in any direction	\$2,187.50	each	7	\$15,312.50	1
Siltanen Park	1.1.4	Parking	Acquire and mount at appropriate heights and locations accessible parking signs for all the stalls	\$150.00	each	6	\$900.00	1
Siltanen Park	1.2.1	Exterior Route	Correct slope of curb ramp side flares to max 10%	\$725.00	each	1	\$725.00	1
Siltanen Park	1.2.2	Exterior Route	Correct curb ramp cross slope to max 2.08%	\$725.00	each	1	\$725.00	1
Siltanen Park	1.2.3	Exterior Route	Install compliant detectable warning at curb ramps and transitions from walkways to vehicular ways as a smart practice	\$235.00	each	1	\$235.00	1
Siltanen Park	1.2.4	Exterior Route	Repair or resurface AR to be free of deterioration	\$2,000.00	each	1	\$2,000.00	1
Siltanen Park	1.2.5	Exterior Route	Ramp steps along AR for access to ballfields	\$4,650.00	each	1	\$4,650.00	1

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Siltanen Park	1.2.6	Exterior Route	Correct or fill gaps along AR	\$68.75	each	6	\$412.50	1
Siltanen Park	1.2.7	Exterior Route	Correct or repair sidewalk cross slope along AR to max 2.08%	\$87.50	sq ft	250	\$21,875.00	1
Siltanen Park	1.2.8	Exterior Route	Correct or repair sidewalk running slope along AR to max 5%	\$87.50	sq ft	300	\$26,250.00	1
Siltanen Park	1.2.9	Exterior Route	Create a compliant 60" by 60" turning space every 400'	\$16.00	sq ft	50	\$800.00	1
Siltanen Park	1.2.10	Exterior Route	See 1.10 below for AR to site elements	\$0.00	n/a	0	\$0.00	1
Siltanen Park	1.4.1	Playground - Surface	Fill and compact EWF surface so that it maintains its accessibility characteristics	\$5,000.00	each	1	\$5,000.00	CO
Siltanen Park	1.4.2	Playground - Surface	Frequently inspect and regularly maintain accessible portions of play area surface that are comprised of loose fill such as EWF so that surface is level with other surfaces	\$0.00	staff time	0	\$0.00	CO
Siltanen Park	1.4.3	Playground - Surface	Establish protocols for regular and frequent inspection and maintenance of accessible playground surface	\$0.00	staff time	0	\$0.00	CO
Siltanen Park	1.5.1	Playground - Transfer System	Lower platform on transfer system to 11" to 18" aff, in the alternative, add and maintain surface fill level to achieve the same	\$250.00	each	1	\$250.00	CO
Siltanen Park	1.6.1	Playground - Ramps	Correct or repair ramp slope to be max 6.25%	\$87.50	sq ft	25	\$2,187.50	CO
Siltanen Park	1.8.1	Playground - GLPC	Lower entry point for one swing to 11" to 24" aff or add fill to achieve the same	\$0.00	staff time	0	\$0.00	CO
Siltanen Park	1.8.2	Playground - GLPC	Lower entry point for rockers to 11" to 24" aff or add fill to achieve the same	\$250.00	each	1	\$250.00	CO
Siltanen Park	1.8.3	Playground - GLPC	Leave as is, remaining GLPC's as the above will meet incentive scoping and one of each type accessible	\$0.00	n/a	0	\$0.00	CO
Siltanen Park	1.10.1	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the ball fields and seating areas	\$48.00	lin ft	200	\$9,600.00	2
Siltanen Park	1.10.2	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the softball fields and seating areas	\$48.00	lin ft	200	\$9,600.00	2
Siltanen Park	1.10.3	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the horse shoes; in the alternative, leave as is and designate horseshoes at other sites in the city as accessible	\$48.00	lin ft	100	\$4,800.00	CO
Siltanen Park	1.10.4	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the majors field and extend to bleachers; in the alternative, leave as is and designate fields at other sites in the city as accessible	\$48.00	lin ft	300	\$14,400.00	CO
Siltanen Park	1.10.5	Park Site	Repair, bevel, or ramp steps to dugouts at majors field; in the alternative, leave as is and designate fields at other sites in the city as accessible	\$4,650.00	each	2	\$9,300.00	CO
Siltanen Park	1.10.6	Park Site	Correct or fill gap at gate to majors field; in the alternative, leave as is and designate fields at other sites in the city as accessible	\$68.75	each	1	\$68.75	CO
Siltanen Park	1.10.7	Park Site	Leave as is, press box citing exception 206.2.7 if elevated more than 12' above ground	\$0.00	n/a	0	\$0.00	CO
Siltanen Park	1.10.8	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the athletic fields	\$48.00	lin ft	150	\$7,200.00	2
Siltanen Park	1.10.9	Park Site	Replace single bowl fountain with hi-low bowl fountain	\$3,998.75	each	2	\$7,997.50	2
Siltanen Park	1.10.10	Park Site	Reorient CFS adjacent to 20% of benches, to not overlap with fountain CFS as a smart practice	\$115.00	each	1	\$115.00	2
Siltanen Park	1.11.1	Shelters	Replace 20% of the picnic tables with one with knee and toe clearance, 19" deep at 27" high and 24" deep at 9" high, with a 36" AR around the table as a smart practice at both	\$800.00	each	2	\$1,600.00	CO
Siltanen Park	1.11.2	Shelters	Correct or repair slopes to enter shelter at BBQ area to max 5% running	\$87.50	sq ft	25	\$2,187.50	CO
Siltanen Park	1.11.3	Shelters	Widen AR to shelter amenities to min 36" wide	\$785.00	each	1	\$785.00	CO
Siltanen Park	1.11.4	Shelters	Replace drinking fountain with a hi-lo bowl fountain	\$3,998.75	each	1	\$3,998.75	CO
Siltanen Park	1.11.5	Shelters	Lower 36" wide portion of counter to max 34" aff	\$785.00	each	1	\$785.00	CO
Siltanen Park	1.11.6	Shelters	Provide required knee and toe clearance at sink	\$785.00	each	1	\$785.00	CO
Siltanen Park	1.11.7	Shelters	Provide cane detectable warning or bollard at base of protrusion	\$150.00	each	1	\$150.00	CO

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Siltanen Park	1.11.8	Shelters	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to picnic area and grills	\$48.00	lin ft	25	\$1,200.00	CO
Siltanen Park	1.12.1	Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.2	Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	1	\$1,250.00	1
Siltanen Park	1.12.3	Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	3	\$6,562.50	1
Siltanen Park	1.12.4	Doors	For all doors along the public circulation route, widen doors to 32" for any doors indicated	\$1,980.00	each	2	\$3,960.00	1
Siltanen Park	1.12.5	Doors	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	22	\$1,512.50	1
Siltanen Park	1.12.6	Doors	For all doors along the public circulation route, replace thresholds at exterior doors with ADA thresholds	\$181.25	each	2	\$362.50	1
Siltanen Park	1.12.7	Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	8	\$2,940.00	1
Siltanen Park	1.12.8	Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors as a smart practice	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.9	Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.10	Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	1
Siltanen Park	1.12.1	Rooms	Employee only areas permit approach, entry, and exit, relocate obstacles such as tables and chairs to create AR through pump room and storage rooms	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.2	Rooms	Relocate obstacles to create AR through parent ed	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.3	Rooms	Employee only areas permit approach, entry, and exit; relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.4	Rooms	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.5	Rooms	Lower sink height to max 34" aff	\$1,700.00	each	1	\$1,700.00	1
Siltanen Park	1.12.6	Rooms	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	1
Siltanen Park	1.12.1	Restrooms	Acquire and mount signage, including Braille, access symbol and correct geometric symbol, mounted on wall, latch side of door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$150.00	each	2	\$300.00	1
Siltanen Park	1.12.2	Restrooms	Lower sinks to max 34" aff to front of rim in both	\$1,700.00	each	2	\$3,400.00	1
Siltanen Park	1.12.3	Restrooms	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	1
Siltanen Park	1.12.4	Restrooms	Widen accessible stalls to min. 60" clear width, 59" depth in both	\$1,963.75	each	2	\$3,927.50	1
Siltanen Park	1.12.5	Restrooms	Remount side grab bar to max 12" from the rear wall at the close end and min 54" on the far end, and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
Siltanen Park	1.12.6	Restrooms	Relocate or recess hand dryers to not interfere with general circulation path in both, protrusions can't be greater than 4"	\$250.00	each	2	\$500.00	1
Siltanen Park	1.12.7	Restrooms	See doors for egress correction	\$0.00	n/a	0	\$0.00	1
Siltanen Park	1.12.8	Restrooms	Replace urinal with one having a 13.5" min depth mounted at max 17" to rim with flush controls max 44" aff	\$2,127.50	each	1	\$2,127.50	1
Siltanen Park	1.12.9	Restrooms	Remount toilet to 17" to 18" from the side wall to centerline in men's	\$1,306.00	each	1	\$1,306.00	1
Siltanen Park	1.12.10	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	1
Siltanen Park	1.12.11	Restrooms	Lower mirror so reflective surface is max 40" aff in women's	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.12.12	Restrooms	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in women's	\$211.25	each	1	\$211.25	1
Siltanen Park	1.12.13	Restrooms	Remount toilet paper dispenser max 7" to 9" from front of toilet, 15" to 48" aff and min 12" above or 1.5" below grab bar in women's	\$0.00	staff time	0	\$0.00	1

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Siltanen Park	1.13.1	Simming Pool	Install pool lift and make it available every hour the pool is open	\$10,000.00	each	1	\$10,000.00	3
Siltanen Park	1.13.2	Simming Pool	Install another handrail at the pool stairs, 20" to 24" from an existing handrail	\$700.00	each	1	\$700.00	3
Siltanen Park	1.13.3	Simming Pool	Repair, bevel, or ramp CIL to upper deck area	\$4,650.00	each	1	\$4,650.00	3
Siltanen Park	1.13.4	Simming Pool	Install adjustable shower head mount to be max 48" at lowest point or add second shower head at a fixed 48" aff	\$525.00	each	1	\$525.00	3
Siltanen Park	1.13.1	Stairs	Assure riser heights of 4" to 7" and treads of min 11" depth and consistent on stairway	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.13.2	Stairs	Repair nosings to be curved or beveled and extend max 1.5" over the tread	\$60.00	each	9	\$540.00	1
Siltanen Park	1.13.3	Stairs	Install detectable warning strip on top tread of each stairway as a smart practice	\$150.00	each	1	\$150.00	1
Siltanen Park	1.13.4	Stairs	Install visual contrast on all treads on front 2" of each	\$15.00	each	9	\$135.00	1
Siltanen Park	1.13.5	Stairs	Install handrails with compliant extensions at top and bottom, mounted 34" to 38" above tread surface	\$700.00	each	1	\$700.00	1
Siltanen Park	1.13.1	Ramps	Correct ramp landing slope to max 2.08% in any direction	\$87.50	sq ft	25	\$2,187.50	1
Siltanen Park	1.13.2	Ramps	Enlarge top landing to be 60" deep and 60" wide	\$1,250.00	each	1	\$1,250.00	1
Siltanen Park	1.13.3	Ramps	Install handrails with compliant extensions at top and bottom	\$700.00	each	1	\$700.00	1
Siltanen Park	1.13.4	Ramps	Install lower handrail min 9" below existing handrail	\$375.00	each	1	\$375.00	1
Siltanen Park	1.13.1	Concessions	Lower 36" wide section of service counter to max 34" aff	\$785.00	each	1	\$785.00	1
Siltanen Park	1.13.2	Concessions	Replace menu with one having pictures and lettering of compliant size based on viewing distance as a smart practice	\$100.00	each	1	\$100.00	1
Siltanen Park	1.13.3	Concessions	Replace oven with one with controls on front of unit	\$2,000.00	each	1	\$2,000.00	1
Siltanen Park	1.13.4	Concessions	Widen clearance between counters to min 60"	\$785.00	each	1	\$785.00	1
Siltanen Park	1.13.5	Concessions	Relocate temporary storage to create CFS at sink, or leave as is until an employee with a disability works here	\$0.00	staff time	0	\$0.00	1
Siltanen Park	1.13.6	Concessions	Remove under sink cabinets to provide knee and toe clearances under sinks and insulate exposed pipes	\$840.00	each	1	\$840.00	1
Siltanen Park	1.13.7	Concessions	Raise menu to min 80" for overhead clearance	\$0.00	staff time	0	\$0.00	1
Skypark	1.1.1	Parking	Create one or more 9' accessible parking stalls, with one 5' adjacent access aisle, with proper signage and striping	\$1,135.00	each	1	\$1,135.00	2
Skypark	1.1.2	Parking	Repaint stalls and add access aisles to be 9' and 5' each in blue paint	\$52.50	each	4	\$210.00	2
Skypark	1.1.3	Parking	Add one van parking sign to one accessible stall and repaint stall and access aisle to 12' and 5' or 9' and 8'	\$202.50	each	1	\$202.50	2
Skypark	1.1.4	Parking	Acquire and mount at appropriate heights and locations accessible parking signs for all the stalls	\$150.00	each	3	\$450.00	2
Skypark	1.1.5	Parking	Repair or correct slope of parking spaces and access aisles to max 2.08% in any direction	\$2,187.50	each	2	\$4,375.00	2
Skypark	1.2.1	Exterior Route	Relocate site amenities to be along AR	\$0.00	staff time	0	\$0.00	2
Skypark	1.2.2	Exterior Route	Repair, bevel, or ramp CIL along AR	\$68.75	inch	6	\$412.50	2
Skypark	1.3.1	Exterior Signage	Mount signage at entrance designating it as accessible	\$150.00	each	1	\$150.00	2
Skypark	1.4.1	Exterior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	2	\$2,500.00	2
Skypark	1.4.2	Exterior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2
Skypark	1.4.3	Exterior Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	3	\$6,562.50	2
Skypark	1.4.4	Exterior Doors	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	8	\$550.00	2
Skypark	1.4.5	Exterior Doors	For all doors along the public circulation route, replace thresholds at exterior doors with ADA thresholds	\$181.25	each	1	\$181.25	2
Skypark	1.4.6	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors	\$0.00	staff time	0	\$0.00	2
Skypark	1.4.7	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	2

# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Skypark	1.4.8	Exterior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	2
Skypark	1.6.1	Interior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2
Skypark	1.6.2	Interior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	1	\$1,250.00	2
Skypark	1.6.3	Interior Doors	For all doors along the public circulation route, replace doors ones having 32" clear width where indicated	\$1,980.00	each	2	\$3,960.00	2
Skypark	1.6.4	Interior Doors	For all doors along the public circulation route, secure edges of carpeting or mats to prevent trip hazard	\$100.00	each	2	\$200.00	2
Skypark	1.6.5	Interior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	1	\$367.50	2
Skypark	1.6.6	Interior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	2
Skypark	1.6.7	Interior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	2
Skypark	1.7.1	Interior Route	Widen AR to min 36" wide where indicated	\$0.00	staff time	0	\$0.00	2
Skypark	1.7.2	Interior Route	Lower operating mechanisms along the interior AR to max 48" aff to the highest operable part	\$0.00	staff time	0	\$0.00	2
Skypark	1.7.3	Interior Route	Relocate storage to provide CFS at hooks	\$0.00	staff time	0	\$0.00	2
Skypark	1.8.1	Public Spaces	Room too small for access, leave as is	\$0.00	n/a	0	\$0.00	2
Skypark	1.8.2	Public Spaces	Relocate protruding objects in spaces indicated or place cane detectable warning or bollard at foot of protrusions	\$150.00	each	2	\$300.00	2
Skypark	1.8.3	Public Spaces	Remove, or relocate storage in CFS at fixtures and operable parts	\$0.00	staff time	0	\$0.00	2
Skypark	1.8.4	Public Spaces	Lower operating mechanisms in spaces indicated to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	2	\$500.00	2
Skypark	1.8.5	Public Spaces	Replace one table in rec room with one that has required knee and toe clearance	\$800.00	each	1	\$800.00	2
Skypark	1.8.6	Public Spaces	Lower sink height to max 34" aff	\$1,700.00	each	1	\$1,700.00	2
Skypark	1.9.1	Employee Spaces	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	2
Skypark	1.9.2	Employee Spaces	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	2
Skypark	1.9.3	Employee Spaces	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	2
Skypark	1.11.1	Restrooms	Remount signage on wall, latch side of the door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$0.00	staff time	0	\$0.00	2
Skypark	1.11.2	Restrooms	Replace side grab bar with a 42" long grab bar, mounted max 12" from the rear wall, min 54" at the far end and 33" to 36" aff in both	\$281.25	each	2	\$562.50	2
Skypark	1.11.3	Restrooms	Remount toilet paper dispenser max 7" to 9" from front of toilet, 15" to 48" aff and min 12" above or 1.5" below grab bar in both	\$0.00	staff time	0	\$0.00	2
Skypark	1.11.4	Restrooms	Remount sink so centerline is minimum 18" from side wall in both	\$1,700.00	each	2	\$3,400.00	2
Skypark	1.11.5	Restrooms	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	2
Skypark	1.11.6	Restrooms	Relocate or recess towel dispensers to not interfere with general circulation path in both, protrusions can't be greater than 4"	\$250.00	each	2	\$500.00	2
Skypark	1.11.7	Restrooms	Acquire and mount signage, including access symbol at staff	\$150.00	each	1	\$150.00	2
Skypark	1.11.8	Restrooms	Remove or relocate garbage can from CFS at sink in staff	\$0.00	staff time	0	\$0.00	2
Skypark	1.11.9	Restrooms	Replace toilet seat, or re-set or replace toilet to 17" to 19" aff in staff	\$1,306.00	each	1	\$1,306.00	2
Skypark	1.11.10	Restrooms	Replace rear grab bar with one 36" long, mounted behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in staff	\$281.25	each	1	\$281.25	2
Skypark	1.11.11	Restrooms	Replace toilet tank with one having flush mechanism on the open side, in the alternative, install an auto flush unit in staff	\$211.25	each	1	\$211.25	2
Skypark	1.11.12	Restrooms	Lower mirror so reflective surface is max 40" aff in both	\$0.00	staff time	0	\$0.00	2
Skypark	1.11.13	Restrooms	Correct or repair slope at sink to max 2.08% in any direction for level CFS in staff	\$87.50	sq ft	52	\$4,550.00	2



# CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Skypark	1.11.14	Restrooms	Repair, bevel, or ramp CIL at floor panel in staff	\$68.75	each	1	\$68.75	2
Skypark	1.11.15	Restrooms	Relocate urinal to not obstruct CFS to transfer to toilet in unisex	\$1,217.50	each	1	\$1,217.50	2
Skypark	1.11.16	Restrooms	Replace urinal with one having a 13.5" min depth mounted at max 17" to rim with flush controls max 44" aff in unisex	\$2,127.50	each	1	\$2,127.50	2
Skypark	1.14.1	Alarms	Upon renovation install audible and visual alarms in all rooms and spaces	\$407.50	each	14	\$5,705.00	2
Skypark	1.15.1	Interior Signage	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	2
Skypark	1.15.2	Interior Signage	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	2
Skypark	1.15.3	Interior Signage	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	3	\$450.00	2
Skypark	1.2.1	Exterior Route - Park	Install compliant detectable warning transitions from walkways to vehicular ways as a smart practice	\$235.00	each	1	\$235.00	2
Skypark	1.2.2	Exterior Route - Park	Maintain surface of AR to be free of sand and debris	\$0.00	staff time	0	\$0.00	2
Skypark	1.2.3	Exterior Route - Park	Maintain plant growth to not obstruct AR	\$0.00	staff time	0	\$0.00	2
Skypark	1.2.4	Exterior Route - Park	Correct or fill gaps along AR	\$68.75	each	5	\$343.75	2
Skypark	1.2.5	Exterior Route - Park	Repair, bevel, or ramp CIL along AR	\$68.75	each	1	\$68.75	2
Skypark	1.2.6	Exterior Route - Park	Correct or repair sidewalk cross slope along AR to max 2.08%	\$87.50	sq ft	25	\$2,187.50	2
Skypark	1.2.7	Exterior Route - Park	Correct or repair sidewalk running slope along AR to max 5%	\$87.50	sq ft	25	\$2,187.50	2
Skypark	1.2.8	Exterior Route - Park	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to all buildings and site elements	\$48.00	lin ft	200	\$9,600.00	2
Skypark	1.3.1	Playground - Entry	Replace existing surface with an accessible surface such as EWF, PIP or tiles, with compliant slopes and CILs	\$50,000.00	each	1	\$50,000.00	2
Skypark	1.4.1	Playground - Surface	See 1.3.1 for correction to playground surface	\$0.00	n/a	0	\$0.00	2
Skypark	1.4.2	Playground - Surface	Fill and compact EWF surface so that it maintains its accessibility characteristics	\$5,000.00	each	1	\$5,000.00	2
Skypark	1.4.3	Playground - Surface	Frequently inspect and regularly maintain accessible portions of play area surface that are comprised of loose fill such as EWF so that surface is level with other surfaces	\$0.00	staff time	0	\$0.00	2
Skypark	1.4.4	Playground - Surface	Establish protocols for regular and frequent inspection and maintenance of accessible playground surface	\$0.00	staff time	0	\$0.00	2
Skypark	1.5.1	Playground - Transfer System	Consider adding second transfer system as a smart practice at both play areas	\$3,550.00	each	2	\$7,100.00	2
Skypark	1.5.2	Playground - Transfer System	Correct transfer step riser height to 8" max and uniform at 2 to 5 play area	\$1,000.00	each	1	\$1,000.00	2
Skypark	1.6.1	Playground - Ramps	Inspect ramp segments and adjust or raise segments to achieve ramp slope of max 6.25%	\$1,000.00	each	1	\$1,000.00	2
Skypark	1.8.1	Playground - GLPC	See 1.3.1 for correction to play area surface	\$0.00	n/a	0	\$0.00	2
Skypark	1.8.2	Playground - GLPC	Lower entry point teeter totter to 11" to 24" aff	\$250.00	each	1	\$250.00	2
Skypark	1.8.3	Playground - GLPC	Relocate play counter to have required 80" overhead clearance	\$250.00	each	1	\$250.00	2
Skypark	1.8.4	Playground - GLPC	Lower reach range of track glide to be max 44" aff	\$250.00	each	1	\$250.00	2
Skypark	1.10.1	Park Site	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the soccer fields and seating areas	\$48.00	lin ft	200	\$9,600.00	2
Skypark	1.10.2	Park Site	Lower grill station cooking surface and counter to max 34" aff; in the alternative, leave as is and designate grills at other sites in the city as accessible	\$250.00	each	1	\$250.00	CO
Skypark	1.10.3	Park Site	Relocate hand crank at grill station to be within required reach range; in the alternative, leave as is and designate grills at other sites in the city as accessible	\$100.00	each	1	\$100.00	CO
Skypark	1.10.4	Park Site	Replace portable toilet with compliant model and place along AR	\$780.00	each	1	\$780.00	2
Skypark	1.10.5	Park Site	Relocate bike racks to be along AR	\$250.00	each	1	\$250.00	2
Skypark	1.10.6	Park Site	Raise bench seat to 17" to 19" aff as a smart practice	\$250.00	each	1	\$250.00	2
Skypark	1.10.7	Park Site	Relocate accessible picnic table to be on accessible surface	\$0.00	staff time	0	\$0.00	2

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Skypark	1.11.1	Shelters	Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to shelter near grill; in the alternative; leave as is and designate other picnic areas in the city as accessible	\$48.00	lin ft	50	\$2,400.00	CO
Skypark	1.11.2	Shelters	Replace 20% of the picnic tables with one with knee and toe clearance, 19" deep at 27" high and 24" deep at 9" high, with a 36" AR around the table as a smart practice	\$800.00	each	6	\$4,800.00	3
Skypark	1.11.3	Shelters	Create AR with crushed and compacted stone or similar outdoor material from shelter to amenities where indicated	\$48.00	lin ft	1	\$48.00	3
Skypark	1.11.4	Shelters	Relocate tables to provide 60" turning space in shelter interior where indicated	\$0.00	staff time	0	\$0.00	3
Skypark	1.11.5	Shelters	Correct or fill gap on shelter interior where indicated	\$68.75	each	2	\$137.50	3
Skypark	1.12.1	Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	2
Skypark	1.12.2	Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	3	\$6,562.50	2
Skypark	1.12.3	Doors	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	7	\$481.25	2
Skypark	1.12.4	Doors	For all doors along the public circulation route, replace hardware with lever hardware mounted between 34" and 48" aff where indicated	\$367.50	each	3	\$1,102.50	2
Skypark	1.12.1	Rooms	Employee only areas permit approach, entry, and exit, relocate obstacles such as tables and chairs to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	2
Skypark	1.12.2	Rooms	Employee only areas permit approach, entry, and exit; relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	2
Skypark	1.12.3	Rooms	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	2
Skypark	1.12.1	Restrooms	Remount signage on wall, latch side of the door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$0.00	staff time	0	\$0.00	2
Skypark	1.12.2	Restrooms	Insulate exposed pipes under one sink in both	\$55.00	each	2	\$110.00	2
Skypark	1.12.3	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in both	\$281.25	each	2	\$562.50	2
Skypark	1.12.4	Restrooms	Replace stall hardware with hardware operable without a tight pinch or grasp and adjust stall doors to be self-closing in both	\$100.00	each	2	\$200.00	2
Skypark	1.12.5	Restrooms	Relocate or recess hand dryers to not interfere with general circulation path in both, protrusions can't be greater than 4"	\$250.00	each	2	\$500.00	2
Skypark	1.12.6	Restrooms	Remount sink to be 18" to centerline from side wall in men's	\$1,700.00	each	1	\$1,700.00	2
Skypark	1.12.7	Restrooms	Replace urinal with one having a 13.5" min depth mounted at max 17" to rim with flush controls max 44" aff in men's	\$2,127.50	each	1	\$2,127.50	2
Skypark	1.12.8	Restrooms	Lower soap dispensers to max 44" aff for a forward reach over counter in men's	\$0.00	staff time	0	\$0.00	2
Waste Water	1.1.1	Parking	Repaint stall to be min 18' long	\$52.50	each	1	\$52.50	3
Waste Water	1.1.2	Parking	Repaint access aisle with compliant striping and text	\$52.50	each	1	\$52.50	3
Waste Water	1.1.3	Parking	Add one van parking sign to one accessible stall and repaint stall and access aisle to 12' and 5' or 9' and 8'	\$202.50	each	1	\$202.50	3
Waste Water	1.1.4	Parking	Repair or correct slope of parking space and access aisle to max 2.08% in any direction	\$2,187.50	each	1	\$2,187.50	3
Waste Water	1.1.5	Parking	Replace signage with compliant signage mounted min 60" aff to bottom of sign or 80" if sign is on the AR	\$150.00	each	1	\$150.00	3
Waste Water	1.2.1	Exterior Route	Create a curb ramp to be max running slope 8.33%, max cross slope 2.08%, having a top landing as wide as the ramp and 36" deep and side flares with a max slope 10% in place of built up ramp	\$1,062.50	each	1	\$1,062.50	3
Waste Water	1.2.2	Exterior Route	Install compliant detectable warning at curb ramp as a smart practice	\$235.00	each	1	\$235.00	3
Waste Water	1.2.3	Exterior Route	Create AR at back entry of admin building	\$48.00	lin ft	100	\$4,800.00	3
Waste Water	1.4.1	Exterior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	3

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Waste Water	1.4.2	Exterior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$125.00	each	7	\$875.00	3
Waste Water	1.4.3	Exterior Doors	For all doors along the public circulation route, correct or repair slope at doorway landing to max 2.08% in any direction for level CFS	\$2,187.50	each	13	\$28,437.50	3
Waste Water	1.4.4	Exterior Doors	For all doors along the public circulation route, widen doors to 32" for any doors indicated	\$1,980.00	each	1	\$1,980.00	3
Waste Water	1.4.5	Exterior Doors	For all doors along the public circulation route, repair, bevel, or ramp CIL at door entries to max .25"	\$68.75	inch	18	\$1,237.50	3
Waste Water	1.4.6	Exterior Doors	For all doors along the public circulation route, fill and maintain gaps at doorways to max .5"	\$68.75	each	4	\$275.00	3
Waste Water	1.4.7	Exterior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	20	\$7,350.00	3
Waste Water	1.4.8	Exterior Doors	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	2	\$1,980.00	3
Waste Water	1.4.9	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open exterior doors	\$0.00	staff time	0	\$0.00	3
Waste Water	1.4.10	Exterior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	3
Waste Water	1.4.11	Exterior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	3
Waste Water	1.6.1	Interior Doors	For all doors along the public circulation route, relocate storage, furniture, and other obstacles to create 60" maneuvering space around doors	\$0.00	staff time	0	\$0.00	3
Waste Water	1.6.2	Interior Doors	For all doors along the public circulation route, provide required maneuvering clearance on push and pull side of doors	\$1,250.00	each	1	\$1,250.00	3
Waste Water	1.6.3	Interior Doors	For all doors along the public circulation route, repair, bevel, or ramp CILs at door entries to max .25"	\$68.75	inch	2	\$137.50	3
Waste Water	1.6.4	Interior Doors	For all doors along the public circulation route, replace threshold at interior doors with ADA thresholds	\$181.25	each	2	\$362.50	3
Waste Water	1.6.5	Interior Doors	For all doors along the public circulation route, replace hardware with lever hardware where indicated	\$367.50	each	3	\$1,102.50	3
Waste Water	1.6.6	Interior Doors	For all doors along the public circulation route, replace doors with ones having sidelight viewing windows max 43" aff	\$990.00	each	2	\$1,980.00	3
Waste Water	1.6.7	Interior Doors	For all doors along the public circulation route, inspect, adjust, and maintain 5 lbf to open interior doors	\$0.00	staff time	0	\$0.00	3
Waste Water	1.6.8	Interior Doors	For all doors along the public circulation route, inspect, adjust, and maintain closing speed on door closers	\$0.00	staff time	0	\$0.00	3
Waste Water	1.6.9	Interior Doors	For employee only doors; make above corrections upon renovation	\$0.00	n/a	0	\$0.00	3
Waste Water	1.7.1	Interior Route	Lower operating mechanisms along the interior AR to max 48" aff to the highest operable part	\$250.00	each	2	\$500.00	3
Waste Water	1.7.2	Interior Route	Relocate protruding objects along the interior AR or place cane detectable warning or bollard at foot of protrusion	\$250.00	each	1	\$250.00	3
Waste Water	1.7.1	Interior Route	Correct tread depth on stairs to 11" minimum and consistent, leave as is if technically infeasible	\$288.75	each	4	\$1,155.00	3
Waste Water	1.7.2	Interior Route	Install detectable warning strip on top tread of each stairway as a smart practice	\$150.00	each	1	\$150.00	3
Waste Water	1.7.3	Interior Route	Install handrails on both sides of stairway, mounted 34" to 38" aff with top and bottom extensions and having a 1.25" – 2" in diameter, or a non-circular grip that has a perimeter dimension of 4"- 6.25" max	\$700.00	each	1	\$700.00	3
Waste Water	1.8.1	Public Spaces	Lower operating mechanisms in break room to max 48" aff to highest operable part; leave as is if employee only operated	\$250.00	each	1	\$250.00	3
Waste Water	1.8.2	Public Spaces	Lower sink height to max 34" aff	\$1,700.00	each	1	\$1,700.00	3
Waste Water	1.9.1	Employee Spaces	Employee only area permit approach, entry, and exit, relocate obstacles to create AR through spaces indicated	\$0.00	staff time	0	\$0.00	3
Waste Water	1.9.2	Employee Spaces	Employee only areas permit approach, entry, and exit, relocate obstacles to create turning space of 60" in spaces indicated	\$0.00	staff time	0	\$0.00	3

## CITY OF SCOTTS VALLEY DRAFT TRANSITION PLAN

Site	Cite	Type of correction	Recommendation	Price/unit	unit type	# of units	Total cost	Phase
Waste Water	1.9.3	Employee Spaces	For all other deficits, leave as is, employee work area pursuant to 2010 Standards 106.5 Defined Terms, until an employee with a disability works here	\$0.00	n/a	0	\$0.00	3
Waste Water	1.11.1	Restrooms	Acquire and mount signage, including Braille, access symbol and correct geometric symbol, mounted on wall, latch side of door, 48" to baseline of Braille characters and 60" to baseline of highest character	\$150.00	each	2	\$300.00	3
Waste Water	1.11.2	Restrooms	Replace stall hardware with hardware operable without a tight pinch or grasp in both	\$100.00	each	2	\$200.00	3
Waste Water	1.11.3	Restrooms	Relocate or recess hand dryers and first aid kits to not interfere with general circulation path in both, protrusions can't be greater than 4"	\$250.00	each	2	\$500.00	3
Waste Water	1.11.4	Restrooms	Remove storage from CFS at sink in men's	\$0.00	staff time	0	\$0.00	3
Waste Water	1.11.5	Restrooms	Lower urinal so that flush control is max 44" aff	\$1,217.50	each	1	\$1,217.50	3
Waste Water	1.11.6	Restrooms	Lower operable parts to max 48" aff in both	\$0.00	staff time	0	\$0.00	3
Waste Water	1.11.7	Restrooms	Remount rear grab bar to behind the toilet, 12" to one side of center and 24" to the other and 33" to 36" aff in men's	\$281.25	each	1	\$281.25	3
Waste Water	1.11.8	Restrooms	Remount toilets to 17" to 18" from the side wall to centerline in women's	\$1,306.00	each	1	\$1,306.00	3
Waste Water	1.11.9	Restrooms	Widen accessible stalls to min. 60" clear width, 59" depth in women's	\$1,963.75	each	1	\$1,963.75	3
Waste Water	1.11.10	Restrooms	Relocate hooks to have required CFS in women's	\$0.00	staff time	0	\$0.00	3
Waste Water	1.13.1	Locker Rooms	Lower hooks and shelves to max 48" aff in both	\$0.00	staff time	0	\$0.00	3
Waste Water	1.13.2	Locker Rooms	Replace operable parts with ones that do not require tight pinch or grasp in both	\$100.00	each	2	\$200.00	3
Waste Water	1.13.3	Locker Rooms	Replace bench in dressing area with one having a seat depth of 20" to 24" deep, 42" long, affixed to the wall or having a back and mounted 17" to 19" aff in both	\$600.00	each	2	\$1,200.00	3
Waste Water	1.13.4	Locker Rooms	Provide appropriate CFS on the exterior of the shower in both	\$110.00	lin ft	6	\$660.00	3
Waste Water	1.13.5	Locker Rooms	Enlarge showers to compliant 30" wide and 60" deep for a roll in shower	\$1,963.75	each	2	\$3,927.50	3
Waste Water	1.13.6	Locker Rooms	Relocate shower controls to compliant location in both	\$333.75	each	2	\$667.50	3
Waste Water	1.13.7	Locker Rooms	Remount shower seat to the correct location and height in the shower in both	\$250.00	each	2	\$500.00	3
Waste Water	1.13.8	Locker Rooms	Designate 5% or no less than 1 locker as accessible, mounting signage having the access symbol and hooks and operating mechanisms max 48" aff in both	\$300.00	each	2	\$600.00	3
Waste Water	1.14.1	Alarms	Upon renovation install audible and visual alarms in all rooms and spaces	\$407.50	each	33	\$13,447.50	3
Waste Water	1.15.1	Interior Signage	Create template for signs that addresses height of sign, size of characters, location of Braille, and other requirements	\$0.00	staff time	0	\$0.00	3
Waste Water	1.15.2	Interior Signage	Implement a sign revision program throughout the building, discriminating between directional signs and signs for permanent spaces	\$0.00	staff time	0	\$0.00	3
Waste Water	1.15.3	Interior Signage	Mount signage at all permanent rooms/spaces having Braille and the international symbol of accessibility, mounted 48" to baseline of lowest character and 60" to the baseline of the highest character sign and on the latch side of the door	\$150.00	each	10	\$1,500.00	3

\$1,148,775.00